

17 is approved for an individual subsurface sewage disposal system with the primary system approved standard and the secondary system approved under Chapter 735, Public Acts of 1986 serving a maximum of 2 bedrooms.

18, 19, 21, 23, 25, 26, and 30-32 are approved for a standard individual subsurface sewage disposal system serving a maximum of 2 bedrooms.


20, 22, 24, 28, and 29 are approved for an individual subsurface sewage disposal system under Chapter 735, Public Acts of 1986 serving a maximum of 3 bedrooms.

27 is not approved for subsurface sewage disposal.

Shaded areas on Lots 17, 21, 22, and 26 are for field use only. Any disturbance in these areas may void the approval.

\* Distribution is approved for subsurface sewage disposal. These drawings shall reflect the maximum size dwelling and the specific location of the primary and secondary disposal areas. These drawings shall not be used for any other purpose without the prior approval of the Commissioner, Health Authority or Representative.

Don McFarlane, *Don McFarlane, Sanitary Engineer*



SUBJECT PROPERTY

